Indian Standard

CODE OF PRACTICE FOR INSTALLATION AND MAINTENANCE OF INTERNAL FIRE HYDRANTS AND HOSE REELS ON PREMISES

(First Revision)

भारतीय मानक

परिसर में भीतरी ग्रग्नि हाइड्रेंट ग्रौर होज़ रीलों के संस्थापन ग्रौर रखरखाव की रीति संहिता

(पहला पुनरीक्षण)

UDC 614.843.1 : 614.843.6 : 006.76

© BIS 1990

BUREAU OF INDIAN STANDARDS MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG NEW DELHI 110002

Price Group 8

May 1990

FOREWORD

This Indian Standard (First Revision) was adopted by the Bureau of Indian Standards on 20 February 1989, after the draft finalized by the Fire Fighting Sectional Committee had been approved by the Civil Engineering Division Council.

The main intentions of provision of first-aid and in-built fire fighting arrangements are to extinguish fire at its inception or to control its spread, to assist the fire services in dealing with the fire and in reducing the losses suffered as a result of fire. Such arrangements are, therefore, supplementary to structural fire safety provisions laid down in relevant Indian Standards. The first-aid fire fighting arrangements cover provision of portable fire extinguishers and first-aid hose reel installation with internal fire hydrants. The selection, installation and maintenance of fire extinguishers are covered in IS 2190 : 1979 'Code of practice for selection, installation and maintenance of portable first-aid fire extinguishers (second revision)'. This standard covers requirements in respect of installation and maintenance of internal fire hydrants and hose reel systems with or without sprinkler installation for different types of buildings. Internal fire hydrants are intended for use by fire brigade or other trained personnel and provide means of delivering considerable quantities of water to extinguish or to prevent the spread of fire. Hose reels delivering smaller quantities of water can be operated even by untrained persons and can be more rapidly brought into action in the early stages of fire. This system is more effective when the premises is provided with an early warning device of any outbreak of fire.

This standard covering wet- and dry-riser system was first published in 1966. The revision cover generally only wet-riser system and the provisions given are in line with the ones followed in advanced countries. The revision also covers the details of water tanks, fire pumps and other components as well as maintenance of system.

For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS 2:1960 'Rules for rounding off numerical values (*revised*)'. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

Indian Standard

CODE OF PRACTICE FOR INSTALLATION AND MAINTENANCE OF INTERNAL FIRE HYDRANTS AND HOSE REELS ON PREMISES

(First Revision)

1 SCOPE

1.1 This standard lays down the requirements of installation and maintenance of internal fire hydrants and hose reels on the premises.

NOTE — The requirements in regard to the installation and maintenance of external fire hydrants are covered in separate Indian Standard.

2 REFERENCES

2.1 The Indian Standards listed in Annex A are necessary adjuncts to this standard.

3 TERMINOLOGY

3.0 For the purpose of this standard, the following definitions shall apply.

3.1 Static Water Tank

Underground or surface water tank, constructed to store water for fire fighting.purpose.

3.2 Terrace Tank

A concrete/masonry/plastic steel tank constructed or erected on terrace of building for fire fighting purpose.

3.3 Priming Tank

A small tank erected in/over the pump house above the fire fighting pumps to keep the pump casing and suction of the fire pump permanently flooded.

3.4 Foot Valve

A valve fixed in the suction strainer of the fire pump which opens only inwards to allow in-rush of water into the pump suction and fire pump when the fire pump is actuated automatically/ manually.

3.5 Jockey Pump

A pump of small capacity which is set to come into operation, automatically with drop in static pressure in the system and to automatically stop when the pre-set pressure is reached again.

3.6 Terrace Pump

An electrically driven pump, located on the terrace connected to a terrace tank with gate valve on suction side and to the internal hydrant system with non-return valve on delivery side.

3.7 Fire Pump

An electric/diesel pump installed at static water tank to charge the wet-riser systems.

3.8 Stand-by Pump

A pump of same capacity as fire pump, driven by a diesel engine or connected to any other alternate source of electric supply.

3.9 Pump Panel

Panel comprising starting, stopping and indicating devices of fire pumps.

3.10 Dry-Riser

An arrangement of fire fighting within the building by means of vertical rising mains not less than 100 mm internal dia with landing valves on each floor/landing which is normally dry but is capable of being charged with water usually by pumping from fire service appliances.

3.11 Down-Comer

An arrangement for fire fighting within the building by means of down-comer mains of not less than 100 mm internal dia, connected to terrace tank through terrace pump, gate valve and nonreturn valve and landing valves on each floor/landing. It is also fitted with inlet connections at ground level and air release valve at roof level for being capable of charged with water by pumping from fire service appliances.

3.12 Wet-Riser-cum-Down-Comer

An arrangement for fire fighting within the building by means of vertical rising mains of not less than 100 mm internal dia with landing valves on each floor/landing connected to terrace tank for fire fighting purpose, through a terrace pump, gate valve and non-return valve near the tank and to a fire pump, gate and non-return valves, over the static tank.

3.13 Wet-Riser

An arrangement for fire fighting within the build-

3.20 Fire Service Connections

This is a 4-way collecting breeching with blank caps (without non-return valve) fixed to a 150-mm dia pipe which is connected to the fire tank for filling from external source.

4 INTERNAL HYDRANT INSTALLATION

4.0 An internal hydrant, installation comprise the following elements:

- a) Static or terrace tank for storing water for fire fighting purpose;
- b) Rise mains, down-comer mains or external mains to feed water from the source to the

connection from a riser system.

3.15 Hose Reel

Fire fighting equipment, consisting of a length of tubing fitted with a shut-off nozzle and connected to a reel, with a permanent connection to a pressurized water supply.

3.16 Air Release Valve

A device by which the trapped air inside a riser main is expelled by water as the system is being charged.

3.17 Air Vessel

A cylindrical vessel installed in the wet-riser system at the bottom and top levels to counteract the water hammer effects.

3.18 Pressure Switch

A switch connected on delivery line of fire pump, or in the body of hydro-pneumatic tank at pre-set pressure level so designed to automatically start the fire pump or jockey pump, as the case may be, when the pressure in the system falls below the pre-set level.

3.19 Fire Service Inlet

A 2- or 3-way collecting head (see 5.1.1 and 5.2.3) with non-return valves fitted to the down-comer/wet-riser main, so that in case of need, fire service can directly pressurize the system with their pump.

Ì

pipes, suitably housed.

4.1 Underground Static Water/Terrace Tanks

4.1.1 Underground Static Water Tanks

The capacity should be as given in Table 1. The tank should not be more than 3.5 m deep having a slope (1:100) and 1 m deep sump of $1 \times 2 \text{ m}$ at the lowest end. The side with sump should preferably be at the front and should have an easily removable manhole cover through which fire engine suction hose can be lowered into the sump for direct pumping. Static water tank should be designed and constructed in conjunction, with domestic tank wherever feasible.

Underground tanks should be provided with compartments with external interconnection at bottom levels having gate valves at both the ends for periodical maintenance/cleaning purpose.

At least two manholes each of adequate size with cover conforming to IS 1726 (Part 1): 1974 should be provided on the tanks (outside the pump house) so as to facilitate fire appliances to draw water from tank when necessary.

Access road to the tank where located outside the building should be at least 6 m in width and the same should be designed suitably to bear a load of fire appliances weighing up to 18 tonnes. The access road should be kept free from encroachment and obstructions at all times.

4.1.2 Terrace Tanks

These should be mounted on suitable girders and plates for equal distribution of load and should be structurally stable and the capacity should be as given in Table 1.

4.2 Fire Pumps and Pump House

4.2.1 The pump house should be located preferably outside the building with a minimum clearance of 6 m from adjoining buildings. The pump house should have adequate natural ventilation with windows, fitted with expanded metal for protection. If the pump house, houses a diesel pump, the exhaust pipe of the diesel engine should be extended to outside the pump house and exhaust discharged at an appropriate height in the open air. The floor of the pump house should be sloped to the farthest end to drain away any water leaking from glands, valves, etc. The pump house should have normal lighting, and also emergency lighting facility, either from a second source or from the generator. If the pump house is located inside the building, either on floor one or in the basement, it should be separated from the rest portion with a wall having 2 hour fire rating and fire check door at its entrance having 1 hour fire rating. For pump house in basement, forced mechanical ventilation should be provided. Pump house in floor one should be located on periphery of building with access directly from outside/open area.

4.2.2 Arrangement of Pumps

The pump house should be of adequate dimension to house all the pumps with suction, delivery pipes, fittings and starter control panel, air vessel, etc, with adequate circulation area. A minimum clearance of 1 m at front and back and 0.75 m on sides and between pumps should be provided for all major pumps exceeding 2.280 l/min capacity. For smaller pumps, including jockey pumps, the clearance required should be 0.75 m at front and back and 0.60 m at sides and between pumps. The head room clearance for all pump houses should be minimum 2.75 m.

The pump control panel which should also be housed in the pump room should of adequate dimension to incorporate : TPN switch and HRC switch both of adequate capacity, selector switch ammeter, voltmeter and phase indicating lights, single phase preventer, start and stop push buttons, auto-manual switch, auxiliary contactors for inter-locking/sequence of operations and all necessary gauges, fittings required to complete the system (the busbar should of copper of appropriate thickness).

Where diesel pump is provided, it should have a

separate panel, also located in the same pump room or adjoining separate room. The panel should have its separate battery, with battery charging device, and auto-manual changeover arrangement. It should incorporate an interlocking device with the main pump panel so that both the electric pump and the diesel pump do not operate simultaneously.

Air vessel of adequate capacity should be installed in the pump house, with pressure switches incorporated on the delivery line. There should be two pressure switches — one with upper and lower limit, for Jockey pump, and another only for lower pressure limit for the main pump. Stopping of main pump should be only by manual push button which should be prominently indicated on the pump panel.

Similar lower pressure limit switch should also be incorporated in the diesel pump to make the start automatically at pre-set drop in pressure.

4.2.2.1 Terrace Pump

The starting of terrace pump should be automatic with pressure switch incorporated in down-comer side so that with opening of any hydrant valve, or hose reel on any floor, it will start automatically with fall in line pressure. In addition, there should be a manual push button starter in the starter control panel to be located on ground floor (floor one) of building. Stopping of pump should be by a push button located in the same starter control. Both the push buttons should be prominently indicated, and should be in different colour for easy identification.

4.2.3 Suction and Delivery Pipe Sizes

The suction and delivery pipes should be of adequate size to meet the functional requirements of the pump, and should not be less than following:

	Suction	Delivery
a) 450 1/min terrace pum	p 50 mm	50 mm
b) 900 l/min ", "	75 mm	50 mm
c) 1 400 l/min " "	100 mm	100 mm
d) 2 280 1/min fire pump	150 mm	150 mm
e) 2 850 1/min " "	200 mm	150 mm
f) 4 540 l/min ,, ,,	250 mm	200 mm

Where a manifold is used to make a common suction header, the size of manifold should be at least equal to the cross section of the main pumps (not counting stand-by pump) suction inlets.

4.2.4 Priming of pumps in all cases should] preferably be by positive suction. This can be

achieved by having the pump house at lower level than the water tank, so as to have a permanently flooded suction. However, where this is not practicable, priming with the help of a priming tank with a foot valve and strainer arrangement may be used. The capacity of priming tank should be 8 times the total volume of the suction pipe, from pump up to the foot valve.

4.2.5 For wet-riser-cum-down-comer system, two pumps of different capacity — one for the wetriser (for static tank) and the other for downcomer system (for terrace tank) should be installed. The pumps should be fed from normal source of power supply and also by an alternative source in case of failure of normal source of supply.

4.2.6 For a wet-riser system two automatic pumps should be installed to feed the wet-rising main, one of which should act as stand-by, each pump should have different source of power and so arranged that when acting as duty pump, it will operate automatically when one or more hydrant/hose reel is opened thus causing a drop in pressure. The stand-by pump should be arranged to operate automatically in case of failure of the duty pump. There should be an interlocking arrangement between two main pumps so that only one should come into operation at a time.

4.2.7 An arrangement for supply of alternative source of power automatically should be provided to drive pumps, etc, in case of failure of normal power supply. The alternative source should be one of the following:

- a) Supply from a diesel generating set of adequate capacity to meet full requirement of fire pump(s) including initial current for direct on line/star-delta starting device over and above the other requirements like automatic fire detection and alarm system, fire lift, staircase and corridor lighting circuits, fire pumps, pressurization system and mechanical exhaust system, etc, with automatic changeover. Fire pump may be connected to diesel engine having same power as that of electric fire pump with automatic changeover in case of power supply failure with interlocking arrangement.
- b) A power supply from separate sub-station for operating emergency services mentioned in 4.2.7(a).

4.2.8 Pump Mounting

The pumps should be mounted firmly on concrete foundation of minimum 75 mm thickness with vibration absorbing layer. The foundation should be at least equal in length to the common base plate of pump, motor and flexible coupling between pump and motor.

For diesel engines and pumps the foundation should be equivalent to railing length of engine and pump with flexible couplings.

All fire pumps should be horizontal split-casting centrifugal type with C. I. casing, bronze impellar, and stainless steel shaft mounted on heavy duty bearings. All metal parts coming in constant contact with water should be suitably treated with anti-corrosive treatment, unless these are of non-ferrous metal.

5 RISERS

5.0 Internal hydrants form part of any of the following systems:

- a) Dry-riser system,
- b) Wet-riser system,
- c) Wet-riser-cum-down-comer system, and
- d) Down-comer system.

5.1 Dry-Riser System (for Cold Region)

5.1.1 Dry-riser main system could be installed in buildings under Group A (i, ii, iii, and iv) (see IS 1641: 1988) where the height of building is above 15 m but not exceeding 24 m up to terrace level and where the water supply for fire fighting is immediately available either through the underground water storage tank/tanks or through water mains/town's main in lieu of provision given in Table 1. The rising main should have two-way fire service inlet without non-return valve at ground level, in front of each such block. It should also be provided with an air-releasing valve at the top level and drain valve at the bottom. The inlet should be about 1 m from the ground level, and easily accessible and unobstructed at all times. Single headed landing valves conforming to IS 5290: 1983 should be provided at all floor landing/staircase enclosures or other suitable easily accessible point.

5.1.2 Dry-riser system does not include hose reel, hose cabinets, fire hose and branch pipes.

5.2 Wet-Riser System

5.2.1 Wet-riser system should be provided in the types of buldings as indicated in Table 1 according to the provision mentioned. The system should consist of a pipe or number of pipes depending on the area and height of the buildings permanently charged with water under pressure with landing valves, hose reel, hose, branch pipe, etc, at every floor level. A provision of pressure differential switch to start the pump automatically, so that water under pressure is available for operational hydrant, hose reels, etc, as soon as the water is drawn from hydrant landing valves causing drop in pressure. The system also incorporates a stand-by pump to come into operation automatically when the normal power supply source fails.

5.2.2 The distribution of wet-riser installation in the building should be so situated as not to be farther than 30 m from any point in the area covered by the hydrant and at a height of 0.75 m to 1 m from the floor. The rising mains should not be more than 50 m apart in horizontal.

5.2.3 Fire service inlet with gate and non-return valve to charge the riser in the event of failure of the static pump directly from the mobile pump of the fire services should be provided on the wet-riser system. The fire service inlet for 100 mm internal diameter rising main should have collecting head with 2 numbers of 63 mm inlets and for 150 mm rising main, collecting head with 4 numbers of 63 mm inlets should be provided.

5.3 Wet-Riser-cum-Down-Comer

5.3.1 A wet-riser-cum-down-comer system should be provided in the type of buildings indicated in Table 1 according to the provision mentioned. However, instead, wet-riser system can be provided with suitable modifications in their requirements as given in 4.2.6.

5.3.2 The position and spacing of wet-riser-cumdown-comers should be similar to wet-riser system (see 5.2).

5.4 Down-Comer System

1.1

5.4.1 Down-comer system should be provided in

type of buildings indicated in Table 1 according to provisions mentioned.

5.4.2 Single headed landing valve, connected to a 100 mm diameter pipe taken from the terrace pump delivery should be provided at each floor/landing. A hose reel conforming to IS 884 : 1985 and directly tapped from the down-comer pipe should also be provided on each floor/landing.

5.5 Fire Service Inlet

5

5.5.1 The following facilities/arrangements should be applicable to wet-riser systems:

- a) A fire service inlet at ground level fitted with a non-return valve should also be provided to the rising main of each zone for charging it by fire service pumps, in case of failure of fire pump. If two rising mains are within a distance of 30 m horizontally a single fire service inlet will be sufficient.
- b) The fire service lnlet should be located and arranged on street side of the building preferably near main entrance, prominently marked and without any obstruction so that fire service can connect hose lines without difficulty.
- c) The inlet should be located inside a box made of 1.6 mm mild steel plate with openable 4 mm thick glass frontage with locking arrangements. The words 'Fire Service Inlet' should be written in letters at least 75 mm in height and 12 mm in width in fluorescent fire red colour (see IS 5: 1978).

5.6 Internal diameter of rising mains/down-comer mains for various types of building, should be as given in Table 2.

Table 1 Typical Fire Fighting Installations/Requirements

.

9

(Clauses 4.1	l.1, 4.1.	5.1.1	5.2.1,	5.3.1,	5.4.1	and 7.2)
---------------	-----------	-------	--------	--------	-------	---------	---

SI	Type of the Building/	Type of			Requirements	
No,	Occupancy	Installation ~	Water	Supply	Pump Caj	pacity
			Underground/ Static Tank	Terrace Tank	Near the Underground Static Tank (Fire Pump)	At the Terrace Level
(1)	(2)	(3)	(4)	(5)	(6)	(7)
II	RESIDENTIAL BUILDINGS (A)				
8	a) Lodging or Rooming Houses (A-1)					
	Dormitories (A-3)					
	i) Up to 15 m in height	Nil	20 000 1	Nil	Nil	Nil
	(NOTE — No provisions are r	necessary for lodgin	g and rooming hous	es with less than 20	persons and dormitories housing	g less than 20 persons.)
	ii) Above 15 m in height but not exceeding 24 m	One down-comer per 1 000 m ³ floor area per floor	50 000 1	10 000 1 (20 000 1 if basement is sprinklered)	Nil	450 l/min giving a pre- ssure not less than 300 kPa (3 kgf/cm ²) at the topmost hyd- rant
	iii) Above 24 m in height but not exceeding 45 m	Wet-riser- <i>cum</i> - down-comer per 1 000 m [*] floor area per floor	100 000 1	10 000 1 (20 000 1 in case basement is sprinklered see 7,12)	2 280 l/min giving a pres- sure not less than 300 kPa (3 kgf/cm ^a) at topmost hydrant	450 l/min giving a pre- ssure not less than 300 kPa (3 kgf/cm ^a) at the topmost hyd- rant
	iv) Above 45 m in height but not exceeding 60 m	One wet-riser per 1 000m ⁹ floor arca per floor. Riser shall be fully charged with ade quate pressure at the topmost hydrant and shall be automatic in operation	150 000 1	Nil	i) 2 280/2 820 1/min giving a pressure not less than 300 kPa (3 kgf/cm ²) at the top- most hydrant. The pump provided will be of multi- stage, multi-outlet (pre- ferably) type with suction and delivery sizes not less than 15 cm dia with low level riser up to 10 storeys and high level riser	Nil

		ii) Entire building to be sprinklered		e e constante de la constante d	ii) A stand-by pump of equal capacity driven by diesel engine or connected to alternate source of power supply from diesel gene- rator set		
	v) Aboye 60 m in height	i) One wet-riser per 1 000 m ² floor	2 00 000	Nil	i) Same as in Item I (a) (iv)(i) above	Ņil	
		area, riser snall be fully charged with adequate pressure at the topmost hyd- rant and shall be automatic in operation			ii) Same as in Item I (a) (iv)(ii) above		
		ii) Entire building to be sprinkler- ed					
	(NOTE — Building with height e	xceeding 24 m with sh	opping area exc	eeding 750 m ² , the s	hopping area to he sprinklered.)		
1	b) One or Two Family Private Dwellings (A-2) Appartment Houses (A-4)						
	i) Up to 15 m in height	Njl	Nil	Nil	Ņįl	Nil	
	(NOTE — Buildings of A-2 of	ccupancy above 15 m	height not to be	permitted.)	,		
	ii) Above 15 m but not exceed- ing 24 m	One down-comer per 1 990 m* floor area per floor	50 000 1	20 000 1	Nil	450 l/min with pressure not less than 300 kPa (3 kgf/cm?) at the topmost hydrant	
	iii) Above 24 m but not exceed- ing 45 m in height (shopping area not exceeding 250 m ³)	One wet-riser-cum- down-comer per 1 000 m ² floor area per floor	50 000 1	20 000 1	1 620 1/min with pressure not less than 300 kPa (3 kgf/cm ²) at the topmost hydrant	450 l/min with pressure not less than 300 kPa (3 kgf/cm ²) at the topmost hydrant	
	iv) Above 24 m but not exceed- ing 45 m in height (shopping area above 250 m ² but not exceeding 750 m ²)	One wet-riser-cum- down-comer per 1 000 m ^a floor area per floor	100 000 1	20 000 1	i) 2 280 l/min with pressure not less than 300 kPa (3 kgf/cm ²) at the top- most hydrant	900 1/min with pressure not less than 300 kPa (3 kgf/cm ²) at the top- most hydrant	
					ii) If the basement car park- ing area does not exceed 750 m ³ , same wet-riser- cum-down-comer pump to feed sprinkler system (see 7.12)		

16:3844.tt 1999

SI	Type of the Building/	Type of			Requirements			
140.	Occupancy	Occupancy Instantion		Supply	Pump Capa	city		
		· · · · · · · · · · · · · · · · · · ·	Underground/ Static Tank	Terrace Tank	Near the Underground Static Tank (Fire Pump)	At the Terrace Level		
(1)	(2)	(3)	(4)	(5)	(6)	(7)		
	v) Above 24 m but not exceed- ing 45 m in height shopping area exceeding 750 m ² but	One wet-riser per 1 000 m ^s floor area (shopping	100 000 1	20 000 1	i) Same as in item I (a) (iv)(i) above	Nil		
	below 1 000 m ³	area to be sprin- klered)			ii) Same as in item I (a) (iv)(ii) above			
	vi) Above 45 m in height but not exceeding 60 m (with-	One wet-riser per 1 000 m ² floor	150 000 1	Nil	i) Same as in item I (a) (iv)(i) above	Nil		
	not exceeding 250 m ²)	area per noor			ii) Same as in item I (a) (iv)(ii) above			
	vii) Above 45 m in height bu not exceeding 60 m with	Same as in item I (a)(v) above	150 000 1	Nil	i) Same as in item I (a) (iv)(i) above	Nil		
	but not exceeding 750 m ^a	. '				ii) Same as in item I (a) (iv)(ii) above	•	
	viii) Above 45 m in height but not exceeding 60 m with shopping area exceeding 750 m ³	One wet-riser per 1 000 m ^a floor area per floor; (shopping area	150 000 1	25 000 1	 i) 2 820 1/min with pressure not less than 300 kPa (3 kgf/cm²) at the top- most hydrant 	Nil		
		to be sprin- klered)	to be sprin- klered)	klered)			ii) Same as in item I (a) (iv)(ii) above	
				 iii) If the basement car park- ing area does not exceed 750 m^a, same wet-riser- cum-down-comer pump to feed sprinkler system 				
	(NOTE — Buildings above 60 m	in height not to be pe	ermitted.)		• · · · · · · · · · · · · · · · · · · ·			
	c) Hotels (A-5)							
	i) Up to 15 m in height with total floor area exceeding 300 m ^a but not more than 1 000 m ^a	One wet-riser-cum- down-comer per 1 000 m ² of floor area per floor	50 000 1	20 000 1	1 620 1/min with pressure not less than 300 kPa (3 kgf/ cm ²) at the topmost hydrant	900 l/min with pressure not less than 300 kPa (3kgf/cm ²) at the top most hydrant		

Table 1 (Continued)

(NOTE -- Hotel, with total floor area not exceeding 300 m², to be exempted from provisions of this requirement.)

- $\mathbf{\infty}$

.

ii) Up to 15 m, in theight with total floor area exceeding 1 000 m ²	One wet-riser for 750 m ^s of floor area per floor. Wet-riser to be fully charged with adequate pressure and automatic in operation	100 000 1	20 000 1 (if sprinklered provided)	2 280 1/min (2 820 1/min if sprinklered) with pressure not less than 300 kPa (3 kgf/ cm ²) at the topmost hydrant	Nil
iii) Above 15 m but not exceed- ing 24 m	One wet-riser for 750 m ^a floor area per floor	150 000 1+50 000 1 for sprinkler for shopping area and if basement used for car park	20 000 l (if sprinklered)	i) 2 280 1/min (2 820 1/min if sprinklered) with pres- sure not less than 300 kPa (3 kgf/cm ³) at the top- most hydrant	Nil
				ii) Same as in Item I (a) (iv) (ii) above	
iv) Above 24 m but not exceed- ing 45 m	đo	200 000 1+50 000 1 extra require- ment for sprink- ler for shopping area and if base-	do	i) Same as in Item I (c) (iii)(i) above ii) Same as in Item I (c) (iii)(ii) above	Nil
		ment used for car park			
v) Above 45 m	do	do	đo	i) 2 820 l/min with pressure not less than 300 kPa (3 kgf/cm ³) at the top- most hydrant	Nil
				ii) Pump of multi-stage type or alternatively break pres- sure wet-riser system by interposing suction tanks and pumps at every 15 floor level	
				iii) Stand-by pump of equal capacity on alternate source of supply	
				iv) All the floors to be sprin- klered, with independent pump	

-

IS 3844 : 1989

v

		Requirements	
Water	Supply	Pump Capac	city
ind/ nk	Terrace Tank	Near the Underground Static Tank (Fire Pump)	At the Terrace Level
	(5)	(6)	(7)
	NU		N:1
	NI	Nil	NII
eding 1	000 m ^s are exempted	ed.)	
	20 000 1	1 620 l/min with pressure not less than 300 kPa (3 kgf/cm ³) at the topmost hydrant	450 l/min with pressure not less than 300 kPa (3 kgf/cm ²) at the top- most hydrant
	20 000 l (if sprinklers are provided in basement)	i) 2 280 l/min with pressure not less than 300 kPa (3 kgf/cm ²) at the top- most hydrant	
		ii) Sprinkler for basement	

Underground/ Static Tank

(2)	(3)	(4)	(5)	(6)
EDUCATIONAL (B) AND INST	ITUTIONAL (C) BU	ILDINGS		
a) Buildings other than Hospitals and Nursing Homes				
i) Up to 15 m in height	Nil	50 000 1	Nil	Ni
(NOIE — Buildings not exce	eding 3 storeys and a	rea not exceedin	g 1 000 m² are exempte	ed.)
ii) Above 15 m in height but not exceeding 24 m height	One wet-riser- <i>cum</i> - down comer per 1 000 m ^s floor area per floor/block	50 000 1	20 000 1	1 620 l/min wi less than 300 l at the topmos
iii) Above 24 m in height but not exceeding 35 m	One wet-riser per 1 000 m ^a floor area per floor/block	199.000 1	20 000 1 (if sprinklers are provided in basement)	i) 2 280 l/min not less t (3 kgf/cm ³ most hydra,
				ii) Sprinkler (see 7.12)
(NOTE — Buildings above 35 m i	in height not to be pe	rmitted.)		· · · · · · · · · · · · · · · · · · ·
b) Hospitals and Nursing Homes				
i) Up to 15 m in height	One down-comer	50 000 1	20 000 1	Nil

One down-comer per 1 000 m² floor area per floor

Type of Installation

900 l/min with pressure not less than 300 kPa (3 kgf/cm²) at the top-most hydrant

(NOTE - Ground floor with beds not exceeding 100 and ground and two upper floors not exceeding 50 beds are exempted.)

ii) Above 15 m in height but not exceeding 24 m	One wet-riser-cum- down-comer for 1 000 m ² floor area per floor	200 000 1+50 000 1 if basement is sprinklered	20 000 1	i) 2 280 1/min (2 820 1/min if sprinklered) with pre- ssure not less than 300 kPa (3 kgf/cm ²) at the top- most hydrant	900 l/min with pres- sure not less than 300 kPa (3 kgf/cm ²) at the topmost hydrant
----------------------------------------------------	--------------------------------------------------------------------------------------	-----------------------------------------------------	----------	-------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------

2 820 1/min if basement is sprinklered (see 7.12)

10

SI No.

(1)

п

Type of the Building/ Occupancy

	iii) Above 24 m in height but not exceeding 35 m	One wet-riser 1 000 m ² floor area per floor	200 000 1+50 000 1 (if partially sprinklered see 7.12)	25 000 l (if partially sprinklered see 7.12)	2 820 l/min with pressure not less than 300 kPa (3 kgf/cm ²) at the topmost hydrant	Nil	
	(NOTE — Buildings above 35 m	in height not to be pe	rmitted.)				
III	ASSEMBLY BUILDINGS (D)						
	i) Up to 15 m in height	One wet-riser-cum- down-comer per 500 m ² floor area per floor	- 50 000 1	20 000 1 (25 000 1 if partially sprinklered see 7.12)	i) 2 280 l/min (2 820 l/min if sprinklered) with pressure not less than 300 kPa (3 kgf/cm ²) at the topmost hydrant	900 1/min with pressure not less than 300 kPa (3 kgf/cm ²) at the topmost hydrant	
					ii) Stand-by pump as alternate source of power supply		
	ii) Above 15 m in height but not exceeding 24 m	do	100 000 1	đo	i) Same as in item III (i) (i) above	do	
					ii) Same as in item III (i) (ii) above		
	iii) Above 24 m in height but not exceeding 35 m	 iii) Above 24 m in height but not exceeding 35 m One wet-riser per 500 m³ floor area per floor. Riser shall be fully charged with ad- equate pressure at the topmost hydrant and shall be automatic in operation 	t One wet-riser per 500 m ^a floor area	150 000 1 + 5 000 1	Nil	i) Same as in item III (i) (i) above	Nil
			if sprinklered (see 7.12)		ii) Same as in item III (i) (ii) above		
	(NOTE — Buildings above 35 m	in height not to be pe	ermitted.)				
IV	BUSINESS (E) AND MERCAN	TILE (F) BUILDING	S				
	i) Up to 15 m in height	One down-comer per 500 m ² floor area per floor	50 000 1	20 000 1	Nil	900 l/min with pressure not less than 300 kPa (3 kgf/cm ²) at the topmost hydrant	
	(NOTE - Buildings with gr	ound and up to two	loors with total area	not exceeding 2 50	0 m ^a is exempted from above pro	ovision.)	
	ii) Above 15 m in height but not exceeding 24 m	One wet-riser-cum down-comer per 500 m ³ floor area per floor. Riser shall be fully charged	- 150 000 1 + 5 000 f for basement sprinklered (see 7.12)	1 20 000 1 if (25 000 1 if par- e tially sprink- lered see 7.12)	i) 2 280 l/min with pressure not less than 300 kPa (3 kgf/cm ²) at the top- most hydrant	do	
	(NOTE — In case of reliab	le town hydrants sys	tem the capacity of v	water tank could be	e reduced to two thirds.)		

IS 3844 : 1989

SI	Type of the Building/	Type of			Requirements	
t40.	Qccupancy	Occupancy Installation Water S		pply	Pump Capac	rity
	م میں میں اور	andra an	Underground/ Static Tank	Terrace Tank	Near the Underground Static Tank (Fire Pump)	At the Terrace Level
(1)	(2)	(3)	(4)	(5)	(6)	(7)
	iii) Above 24 m in height but not exceeding 45 m	One wet-riser per 500 m ² floor area	150 000 1+50 000 1 if basement is	Nil	i) Same as in item IV (ii) (i) above	NII
	and a second second Second second	per floor. Riser shall be fully charged with	sprinklered (see 7.12)		ii) Stand-by pump as alter- nate source of power supply	
	n de la construcción de la desarra. La construcción de la desarra de la desar La construcción de la desarra de la desar	sure at the top- most hydrant			*****	
	an an an an an an ann an ann an Arraigh	and shall be automatic in operation				
	iv) Above 45 m in height	i) do ii) All the floors	200 000 1+50 000 1 if sprinklered (see 7.12)	Nil	i) 2 820 l/min with pressure not less than 300 kPa (3kgf/cm ²) at the topmost	Nil
		and basements if any to be sprinklered	es providencia 1975 - 1975 - 1975 1976 - 1976 1977 - 1977 1977 - 1977 - 1977 - 1977 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 - 1977 -		ii) Pump of multi-stage type or alternatively break pressure wet-riser system by interposing suction tanks and pumps at every 15 floor level	÷
	a an	· .			Stand-by pump of equal capacity on alternate source of supply	i in
v	INDUSTRIAL BUILDINGS (G)				and the second secon	
	i) Up to 15 m in height	One wet-riser- cum-down-comer for 500 m ² floor area per floor	50 000 1	20 000 1	i) 2 280 l/min with pressure not less than 300 kPa (3 kgf/cm ²) at the top- most hydrant	900 l/min with pressure not less than 300 kPa (3 kgf/cm ^a) at the topmost hydrant
	(NOTE Buildings with gr	ound floor only or w	ith ground and floor	s with total floor	area not exceeding 1 000 m ^a to be	exempted.)
	ii) Above 15 m in height but not exceeding 24 m	Wet-riser	150 000 1		i) Same as in item V (i) (i) above	Nil
	an an that are at the second	e e ser e ser	an a		ii) Stand-by pump of equal capacity on alternate source of power supply	

 Table 1 (Concluded)

12

VI STORAGE (H) AND HAZARDOUS (J) BUILDINGS

i) Single storey buildings	Ring main type hydrant system with mains, fully charged with adequate pressure at the remote hydrant	100 000 1 (for aggregate area not exceed- ing 1 000 m ³) 150 000 litres (for area exceed- ing 1 000 m ³)	Nii	 i) 2 280 1/min (2 850 1/min if sprinklered) with pre- ssure not less than 300 kPa (3 kgf/cm²) at the topmost hydrant ii) Stand-by pump of equal capacity on alternate source of power supply if area exceeds 1 000 m² 	Nil
ii) Up to 15 m in height	One wet-riser- cum-down-comer for 500 m ^a floor area per floor	150 000 1	20 000 1	 i) Same as in item IV (i) (i) above ii) Same as in item IV (i) (ii) above 	900 l/min with pres- sure not less than 300 kPa (3 kgf/cm ²) at the topmost hydrant
(NOTE — Hazardous buildings ab	ove 15 m not to be p	ermitted.)			
iii) Storage buildings above 15 m in height but not exceeding 24 m	One wet-riser- cum-down-comer for 500 m ^a floor arca	150 000 1	_	 i) Same as in item IV (i) (i) above ii) Same as in item IV (i) (ii) above 	-
(NOTE Storage building above 3	24 m not to be permi	itted.)	<i></i>		

IS 3844 : 1989

Table 2 Size of Mains

(Clause 5.6)

Size of the Mains		Type of Building (see IS 1641 : 1988)	Height of Building
(1)		(2)	(3)
100 mm single outlet landing val	ves	I) Residential buildings (A)	
		i) Lodging housing)
		ii) Dormitory	
		iii) Family private dwellings	Above 15 m and not exceeding 45 m
		iv) Apartment houses	
		v) With shopping area not exceeding 250 m ²	J
		vi) Hotel buildings up to 3 star grade	Above 15 m in height but not exceed- ing 24 m and area not exceeding 600 m ^a per floor
do	II)	Educational buildings (B)	Above 15 m but not exceeding 35 m
do	III)	Institutional buildings (C)	
		a) For hospitals and sanito- rium with beds not exceeding 100	Above 15 m but not exceeding 25 m
		b) For custodial places and mental institutions	Above 15 m but not exceeding 35 m
do	IV)	Assembly buildings (D)	Above 15 m but not exceeding 24 m and total floor area not exceeding 500 m ³ /floor
đo	V)	Business buildings (E)	Above 15 m but not exceeding 24 m
đo	VI)	Mercantile buildings (F)	Above 15 m but not exceeding 24 m
do	VII)	Industrial buildings (G)	Above 15 m but not exceeding 24 m
150 mm with twin outlet landing valves	VIII)	All buildings classified under (i) to (iv)	Above 45 m
do	IX)	All buildings classified under (v) above with shop- ping area not exceeding 250 m ^a	Above 24 m
do	X)	All buildings classified under I (vi) above	Above 24 m and area exceeding 600 m ²
đo	XI)	Hotel buildings of 4 star and 5 star grade	Above 15 m
đo	XII)	All buildings classified under II and III above	Above 25 m/35 m as applicable
đo	XIII)	All buildings classified under IV above	Above 24 m and area exceeding 500 m ^a /floor
đo	XIV)	All buildings classified under V above	Above 24 m
đo	XV)	All buildings classified under VI above	Above 24 m but not exceeding 35 m
do	XVI)	All buildings classified under VII above	Above 24 m but not exceeding 35 m
do	XVII)	All storage buildings (H)	Above 10 m but not exceeding 24 m

,

5.7 The rising mains/down-comer mains should be of galvanized iron pipes conforming to medium class of IS 1239 (Part 1): 1979 and their fittings should be according to IS 1239 (Part 2): 1982.

5.8 The position of risers should be located within lobby approach staircase or within the staircase enclosure when there is no lobby. However, the risers or the landing valves connected to the risers should not obstruct the means of escape, neither reduce the width of the passage of staircase in any way.

5.9 Landing valves should be installed on each floor level and on the roof, if accessible, in such a way that control line of landing valve is 1 to 1.2 m above the floor level. In the event of pump pressure being excessive at the lower floor levels in tall buildings a reducer should be provided in the landing valves to limit operating pressure to 5.5 kg/cm^2 (0.5 N/mm^2). The hoses, nozzles and branch pipes should be kept adjacent to the landing valves in wall boxes or in recesses.

5.10 In buildings with basements, the internal hydrants as well as the hose reel installations should be extended to cover the basement area also, over and above sprinkler system, as necessary.

5.11 A minimum of two hydrants connected to internal hydrant system should be provided within the courtyard of the buildings. These should preferably be sited adjacent to the roads along the compound wall and facilities provided for fire brigade appliances.

5.12 Fire hoses should be of sufficient length to carry water from the nearest source of water supply to the most distant point in the area covered by a hydrant, by the normal route of travel. For each internal hydrant (single headed), there should be a total length of not less than 30 m of 63 mm conforming to Type A of IS 636: 1988 or provided in two lengths of not more than 15 m each wire wound with coupling together with branch pipe conforming to IS 2871: 1983. Spare hose pipes, landing valves lugs, valves wheel, etc. Minimum of 10 percent of each item should always be kept in stock readily available. Such spare hoses also should be in length of not more than 15 m complete with coupling. Hoses and accessories should be kept in hose cabinet painted fire red (see IS 5: 1978) and constructed preferably of wood with glass front. Wall boxes constructed of cast iron or sheet iron should be painted at regular intervals to obviate rusting and consequent damage to hose. A set of spare rubber washers packed in French chalk for the purpose of preservation should be kept readily available.

5.13 To avoid pilferage, components like landing valves, hose couplings, branch pipes, lugs, etc, made of aluminium alloy are recommended depending on weather conditions.

5.14 Unless impracticable by structural considerations, the landing valves should always be housed in hose boxes. Such hose boxes should be made of MS plates of 2 mm minimum thickness with glass front. The size of the box should be adequate to accommodate single/double headed landing valves with 2 or 4 lengths of fire hose each of 15 m length, and one or two branch pipes. The hose reel may or may not be accommodated inside the hose box. If the hose box is also to accommodate the hose reel, it should be of adequate dimensions. For single headed landing valve, the front opening glass door may be of single leaf, but for double landing valve, double leaf doors are recommended. The location of the riser main, along the landing valves and hose reel, etc, should be such as to leave enough clearance on both sides and also below the landing valve, for smooth operations. The landing valves should be so fitted to the riser main, that when the fire hose is connected to it, and charged with water under pressure, it will not form any kink. Consideration should also be given to allow adequate spaces around the valve to permit maintenance and testing.

5.14.1 For such buildings where narrow space does not permit fixing of hose boxes, the fire hoses, and hose reel could be fixed in suitable niches through which the riser main has been taken up. In such cases only a glass facing fixed on a frame of angle iron may be used. However, these may be used only for residential apartments.

5.15 Building fitted with wet-riser/wet-riser-cumdown-comer mains should have access roads to within 6 m from the boundary line of the building and the nearest wet-riser stack should not be more than 15 m from the boundary line of the building.

6 HOSE REELS

6.1 In addition to wet-riser systems, first aid hose reels should be installed on all floors of buildings above 15 m in height. The hose reel should be directly taken from the wet-riser pipe by means of a 37 mm socket and pipe to which the hose reel is to be attached. When taken from the landing valve, it should be connected to one of the female couplings of the double outlet landing valves of the wetriser installation by means of an adapter. The hose reel should conform to Type A of IS 884 : 1985.

6.2 The hose reel should be sited at each floor level, staircase, lobby or mid-landing adjacent to exits in corridors in such a way that the nozzle of the hose can be taken into every room and within 6 m of any part of a room keeping in view the layout and obstructions. The doors provided for the hose reel recesses should be capable of opening to approximately 180°. When installation is in open areas, the position should be above head height and the nozzle retainer and the inlet valve should be at about 900 mm above floor level.

6.3 It is essential that the hose reels remain unobstructed and that they should be available for use at all times.

6.4 In buildings that have large open floor areas such as warehouses, the stacking arrangement should provide for unobstructed access to the hose reel. It may also be considered necessary to provide guard rails around the hose reel position to prevent stacking adjacent to it, care being taken that the guard rails do not obstruct the operation of the hose.

6.5 The length of hose reels should be such that no part of the floor so protected is more than 6 m away from the nozzle when the hose reel is fully extended.

6.6 The hose reels should preferably be installed in recesses so that they do not form obstructions on a route of escape.

6.7 Hose reel brackets should be firmly fixed to the wall.

7 WATER SUPPLIES AND PUMPING ARRANGEMENTS

7.1 For wet-riser mains and hose reels it is essential that pressures and flows should at all times be adequate to serve the designed number of jets likely to be used. This is irrespective of the source of water supply.

7.2 For wet-riser-cum-down-comer system, two pumps of different capacities (see Table 1) one for the wet-riser and the other for down-comer system should be installed. The pumps should be fed from normal source of power supply and also by an alternative source in case of failure of normal source.

7.3 For a wet-riser system, two automatic pumps should be installed to independently feed the wetriser main, one of which should act as stand-by, each pump being supplied by a different source of power. The pump shall be arranged so that when acting as duty-pump, operate automatically when one or more hydrant is opened thus causing a drop in pressure. The stand-by pump should be arranged to operate automatically in case of failure of the duty pump. The system should have an interlocking arrangement so that only one of the pumps operate at a time. 7.4 Priming of the main pump and terrace pump in case of wet-riser-cum-down-comer, or both the pumps in case of wet-riser installation, should be automatic. This can be achieved either by having flooded suction, or by a priming tank with foot valve arrangement. However, a flooded suction is preferable.

7.5 Arrangements for draining a wet-riser main should be incorporated to enable any necessary repairs to be carried out.

7.6 To allow any trapped air in the rising main to escape when water is pressurized into system, air release valve should be incorporated above the highest outlet of each main.

7.7 To reduce the risk of hose bursting, arrangements should be made so that when the water is shut off at the nozzle the static pressure in any line of hose connected to a landing valve does not exceed 700 kPa (7 kgf/cm^2).

7.8 To reduce excess pressure at ground floor or lower floors [in excess of 400 kPa (4 kgf/cm²) suitable arrangement (orifice flange or other measure)] should be incorporated in the landing valves.

7.9 For external hydrants, piping (water main) should be laid preferably underground, to avoid it getting damaged by moving vehicles, etc. To avoid rusting, underground pipes should be either of cast iron conforming to IS 1536 : 1976 or MS/GI [conforming to IS 1239 (Part 1) : 1979], in which case it should be properly treated with a coat of primary paint with two coats of bitumen paint. The pipes should be properly supported on pedestals — not more than 3 m apart. Underground pipes should be laid 1 m below to avoid damage during road repair, etc, and at road crossings where heavy vehicles are expected to pass, it should pass through RCC pipe for additional protection.

7.10 Air Vessel

To take care of small leakages in the system, an air vessel of appropriate size should be installed and connected to the wet-riser main.

7.11 Jockey Pump

For bigger buildings or major installations, where chance of such leakage is very considerable, it is desirable to install a small pump (using a small motor and 200/300 l/min pump) with pressure switches for automatic start and stop.

7.12 Using Wet-Riser System Pump for Partial Sprinkler System

In main high rise buildings, the basement is used for car parking/housing transformers/or storages and other floors may be used as shopping areas, departmental stores, etc, the total area used for such purpose being small, in such cases, the same wet-riser pump may be used for feeding the sprinkler system provided that:

- a) the total area of the basement to be protected is less than 500 m^2 .
- b) the total area utilized as shops departmental stores is less than 1 000 m².
- c) the pump has a capacity of at least 2 850 l/min with suitable motor.
- d) a separate stand-by pump of equal capacity is installed, either diesel driven, or by a generator of appropriate capacity — as indicated in 4.2.7.

8 INITIAL TESTING

8.1 The system should be tested before use by charging with water to a pressure of 700 kPa (7 kgf/cm^2) measured at the inlet for a period of at least 30 minutes. During this period, an inspection of the system should be done to check that no leakage of water is taking place at any of the joints or landing valves and the pressure in the system does not drop by more than 50 kPa (0.5 kgf/cm^2).

8.2 After the test in accordance with 8.1 is completed, a flow test should be carried out.

9 MAINTENANCE

9.1 Periodic inspections of the vicinity of all hydrants should also be done to ensure that there are no obstructions impeding accessibility and that hydrant indicator plates are in position.

9.2 Periodic inspection should be done to ensure that all isolating valves for systems are kept locked in an 'open' position. Also flow and pressure should be checked to ensure that supplies have not deteriorated, leakage does not exist and that the entire system is in satisfactory condition.

9.3 Inlets, landing valves, drain valves, door hinges and locking arrangements to the inlet and landing valve boxes should be inspected every six months. Special attention should be given to all valves, spindles, glands and washers to ensure that they are in satisfactory condition, so that all equipment is ready for immediate use. Also following checks should be done:

- a) Check on the cleanliness of storage tanks, and
- b) Thorough check of the jockey pumps and their associated mechanical and electrical equipment.

9.4 Where any outlet on the rising mains is found to be defective and no replacement is immediately available, the whole valve assembly should be removed from the main and be replaced with a blanking off plate or plug, in order that the system remains operative.

9.5 Hose reels should be subjected to regular inspection to ensure that the inlet valve, the automatic on/off valve, if any, glands, tubing and shut off nozzle are sound and free from leaks, and also to ensure that the outlet of the nozzle is not choaked.

9.6 If jockey pumps have been installed, such pumps and the associated mechanical and electrical equipments should also be checked.

9.7 Once a year the hose reels should be completely run out and subjected to operational water pressure to ensure that the hose is in good condition and that the coupling joints are watertight. A flow test should be carried out to ensure that discharge of at least 0.5 l/s (30 l/min) is achieved. If it is not possible to test every hose reel, at least the highest reel on each rising main should be tested.

9.8 It is essential that all defects are rectified in the shortest possible time, to ensure that the fixed fire-fighting equipment is restored to a satisfactory condition in as short a time as possible.

9.9 Where, due to unforeseen difficulties it is necessary to leave an installation not available for use, the fire service should be informed immediately in order that alternative arrangements may be made to cover this deficiency should the need arise. In addition, a suitable notice to indicate that the installation is not available for use should be placed in a prominent position. IS 3844 : 1989

ANNEX A

(Clause 2.1)

LIST OF REFERRED INDIAN STANDARDS

IS No.	Title	IS No.	Title
IS 5 : 1978	Colours for ready mixed paints and enamels (third revision)	IS 1536 : 1976	Centrifugally cast (spun) iron pressure pipes for waters, gas and sewage (second revision)
IS 636 : 1988	Non-percolating flexible fire fighting delivery hose (<i>third revision</i>)	IS 1641 : 1988	Code of practice for fire safety of buildings (gene- ral): General principles
IS 884 : 1985	First-aid hose-reel for fire fighting (<i>first revision</i>)		and fire grading and classification (first revision)
IS 1239 (Part 1): 1979	Mild steel tubes, tubulars and other wrought steel fittings : Part 1 Mild steel tubes (fourth revision)	IS 1726 (Part 1): 1974	Cast Iron manhole covers and frames : Part 1 General requirements (second revision)
IS 1239 (Part 2): 1982	Mild steel tubes, tubulars and other wrought steel fittings : Part 2 Mild steel tubulars and other wrought	IS 2871 : 1983	Branch pipe, universal, for fire fighting purposes (first revision)
	steel pipe fittings (third revision)	IS 5290 : 1983	Landing values (second revision)

Standard Mark

The use of the Standard Mark is governed by the provisions of the Bureau of Indian Standards Act, 1986 and the Rules and Regulations made thereunder. The Standard Mark on products covered by an Indian Standard conveys the assurance that they have been produced to comply with the requirements of that standard under a well defined system of inspection, testing and quality control which is devised and supervised by BIS and operated by the producer. Standard marked products are also continuously checked by BIS for conformity to that standard as a further safeguard. Details of conditions under which a licence for the use of the Standard Mark may be granted to manufacturers or producers may be obtained from the Bureau of Indian Standards.

Bureau of Indian Standards

BIS is a statutory institution established under the Bureau of Indian Standards Act, 1986 to promote harmonious development of the activities of standardization, marking and quality certification of goods and attending to connected matters in the country.

Copyright

BIS has the copyright of all its publications. No part of these publications may be reproduced in any form without the prior permission in writing of BIS. This does not preclude the free use, in the course of implementing the standard, of necessary details, such as symbols and sizes, type or grade designations. Enquiries relating to copyright be addressed to the Director (Publications), BIS.

Revision of Indian Standards

Indian Standards are reviewed periodically and revised, when necessary and amendments, if any, are issued from time to time. Users of Indian Standards should ascertain that they are in possession of the latest amendments or edition Comments on this Indian Standard may be sent to BIS giving the following reference:

Doc: No. BDC 22 (4454)

Amendments Issued Since Publication				
Amend No.	Date of Issue	Text Affected		
		· · · ·		
<u></u>				
BU	REAU OF INDIAN STANDARDS	3		
Headquarters :				
Manak Bhavan, 9 Bahadur Shah Z Telephones : 331 01 31, 331 13 7	afar Marg, New Delhi 110002 5	Telegrams : Manaksanstha (Common to all Offices)		
Regional Offices :		Telephone		
Central : Manak Bhavan, 9 Bahao NEW DELHI 110002	iur Shah Zafar Marg	331 01 31 331 13 75		
Eastern: 1/14 C. I. T. Scheme VII CALCUTTA 700054	M, V. I. P. Road, Maniktola	37 86 62		
Northern : SCO 445-446, Sector 3	5-C, CHANDIGARH 160036	2 18 43		
Southern : C. I. T. Campus, IV Ca	ross Road, MADRAS 600113	41 29 16		
Western : Manakalaya, E9 MIDC BOMBAY 400093	, Marol, Andheri (East)	6 32 92 95		
Branches : AHMADABAD. BAN FARIDABAD. GHAZ PATNA. TRIVANDR	GALORE. BHOP <mark>AL. BHUBA</mark> NES IABAD. GUWAHATI. HYDERAB UM.	SHWAR. COIMBATORE. BAD. JAIPUR. KANPUR.		